

## LABORATORY REPORT

If you have any questions concerning this report, please do not hesitate to call us at City of Fountain Water Department at (719) 322-2072.

*This report may not be reproduced, except in full, without written approval from EEA.*

## STATE CERTIFICATION LIST

State	Certification	State	Certification
Alabama	40700	Missouri	880
Alaska	IN00035	Montana	CERT0026
Arizona	AZ0432	Nebraska	NE-OS-05-04
Arkansas	IN00035	Nevada	IN00035
California	2920	New Hampshire*	2124
Colorado	IN00035	New Jersey*	IN598
Colorado Radiochemistry	IN00035	New Mexico	IN00035
Connecticut	PH-0132	New York*	11398
Delaware	IN035	North Carolina	18700
Florida*	E87775	North Dakota	R-035
Georgia	929	Ohio	87775
Hawaii	IN035	Oklahoma	D9508
Idaho	IN00035	Oregon (Primary AB)*	4074
Illinois*	200001	Pennsylvania*	68-00466
Illinois Microbiology	17767	Puerto Rico	IN00035
Illinois Radiochemistry	IN00035	Rhode Island	LAO00343
Indiana Chemistry	C-71-01	South Carolina	95005
Indiana Microbiology	M-76-07	South Dakota	IN00035
Iowa	098	Tennessee	TN02973
Kansas*	E-10233	Texas*	T104704187-18-12
Kentucky	90056	Texas/TCEQ	TX207
Louisiana*	LA014	Utah*	IN00035
Maine	IN00035	Vermont	VT-8775
Maryland	209	Virginia*	460275
Massachusetts	M-IN035	Washington	C837
Michigan	9926	West Virginia	9927 C
Minnesota*	018-999-338	Wisconsin	999766900
Mississippi	IN035	Wyoming	IN035
EPA	IN00035		

\*NELAP/TNI Recognized Accreditation Bodies

## Laboratory Report

Client: City of Fountain  
Attn: Jasson Palmer  
116 South Main  
Fountain, CO 80817

Report: 468719  
Priority: Standard Written  
Status: Final  
PWS ID: CO0121275

Sample Information					
EEA ID #	Client ID	Method	Collected Date / Time	Collected By:	Received Date / Time
4459697	AGA N4	537	10/17/19 15:00	Client	10/18/19 10:00
4459698	AGA S1	537	10/17/19 15:02	Client	10/18/19 10:00
4459699	AGA S2	537	10/17/19 15:04	Client	10/18/19 10:00
4459700	AGA S4	537	10/17/19 15:06	Client	10/18/19 10:00
4459701	AGA RAW	537	10/17/19 15:08	Client	10/18/19 10:00
4459702	Well3 W4	537	10/17/19 15:15	Client	10/18/19 10:00
4459703	Well3 E1	537	10/17/19 15:17	Client	10/18/19 10:00
4459704	Well3 E2	537	10/17/19 15:19	Client	10/18/19 10:00
4459705	Well3 E3	537	10/17/19 15:22	Client	10/18/19 10:00
4459706	Well3 RAW	537	10/17/19 15:24	Client	10/18/19 10:00

### Report Summary

Detailed quantitative results are presented on the following pages. The results presented relate only to the samples provided for analysis.

*Note: This report may not be reproduced, except in full, without written approval from EEA.*

*Kelly Blackburn ASM*

Authorized Signature

Title

11/01/2019

Date

Client Name: City of Fountain

Report #: 468719

Client Name: City of Fountain

Report #: 468719

Sampling Point: AGA N4

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	2.0	13	ng/L	10/25/19 07:47	10/26/19 12:04	4459697
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	2.0	2.2	ng/L	10/25/19 07:47	10/26/19 12:04	4459697
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	2.0	4.1	ng/L	10/25/19 07:47	10/26/19 12:04	4459697
375-95-1	Perfluorononanoic acid (PFNA)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 12:04	4459697
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 12:04	4459697
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	2.0	3.3	ng/L	10/25/19 07:47	10/26/19 12:04	4459697

Sampling Point: AGA S1

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	2.0	4.8	ng/L	10/25/19 07:47	10/26/19 12:38	4459698
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 12:38	4459698
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 12:38	4459698
375-95-1	Perfluorononanoic acid (PFNA)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 12:38	4459698
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 12:38	4459698
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 12:38	4459698

Sampling Point: AGA S2

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 12:55	4459699
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 12:55	4459699
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 12:55	4459699
375-95-1	Perfluorononanoic acid (PFNA)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 12:55	4459699
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 12:55	4459699
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 12:55	4459699

Client Name: City of Fountain

Report #: 468719

Sampling Point: AGA S4

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 13:12	4459700
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 13:12	4459700
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 13:12	4459700
375-95-1	Perfluorononanoic acid (PFNA)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 13:12	4459700
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 13:12	4459700
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	2.0	< 2.0	ng/L	10/25/19 07:47	10/26/19 13:12	4459700

Sampling Point: AGA RAW

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	2.0	<b>30</b>	ng/L	10/25/19 08:01	10/26/19 01:56	4459701
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	2.0	<b>8.7</b>	ng/L	10/25/19 08:01	10/26/19 01:56	4459701
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	2.0	<b>39</b>	ng/L	10/25/19 08:01	10/26/19 01:56	4459701
375-95-1	Perfluorononanoic acid (PFNA)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 01:56	4459701
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537	---	2.0	<b>26</b>	ng/L	10/25/19 08:01	10/26/19 01:56	4459701
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	2.0	<b>24</b>	ng/L	10/25/19 08:01	10/26/19 01:56	4459701

Sampling Point: Well3 W4

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	2.0	<b>2.3</b>	ng/L	10/25/19 08:01	10/26/19 02:13	4459702
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 02:13	4459702
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 02:13	4459702
375-95-1	Perfluorononanoic acid (PFNA)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 02:13	4459702
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 02:13	4459702
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 02:13	4459702

Client Name: City of Fountain

Report #: 468719

Sampling Point: Well3 E1

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 02:30	4459703
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 02:30	4459703
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 02:30	4459703
375-95-1	Perfluorononanoic acid (PFNA)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 02:30	4459703
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 02:30	4459703
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 02:30	4459703

Sampling Point: Well3 E2

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 03:04	4459704
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 03:04	4459704
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 03:04	4459704
375-95-1	Perfluorononanoic acid (PFNA)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 03:04	4459704
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 03:04	4459704
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 03:04	4459704

Sampling Point: Well3 E3

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 03:21	4459705
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 03:21	4459705
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 03:21	4459705
375-95-1	Perfluorononanoic acid (PFNA)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 03:21	4459705
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 03:21	4459705
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 03:21	4459705

Client Name: City of Fountain

Report #: 468719

Sampling Point: Well3 RAW

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537	---	2.0	<b>19</b>	ng/L	10/25/19 08:01	10/26/19 03:38	4459706
375-85-9	Perfluoroheptanoic acid (PFHpA)	537	---	2.0	<b>6.9</b>	ng/L	10/25/19 08:01	10/26/19 03:38	4459706
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537	---	2.0	<b>34</b>	ng/L	10/25/19 08:01	10/26/19 03:38	4459706
375-95-1	Perfluorononanoic acid (PFNA)	537	---	2.0	< 2.0	ng/L	10/25/19 08:01	10/26/19 03:38	4459706
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537	---	2.0	<b>28</b>	ng/L	10/25/19 08:01	10/26/19 03:38	4459706
335-67-1	Perfluorooctanoic acid (PFOA)	537	---	2.0	<b>16</b>	ng/L	10/25/19 08:01	10/26/19 03:38	4459706

† EEA has demonstrated it can achieve these report limits in reagent water, but can not document them in all sample matrices.

Reg Limit Type:	MCL	SMCL	AL
Symbol:	*	^	!

## Lab Definitions

**Continuing Calibration Check Standard (CCC) / Continuing Calibration Verification (CCV) / Initial Calibration Verification Standard (ICV) / Initial Performance Check (IPC)** - is a standard containing one or more of the target analytes that is prepared from the same standards used to calibrate the instrument. This standard is used to verify the calibration curve at the beginning of each analytical sequence, and may also be analyzed throughout and at the end of the sequence. The concentration of continuing standards may be varied, when prescribed by the reference method, so that the range of the calibration curve is verified on a regular basis. CCL, CCM, and CCH are the CCC standards at low, mid, and high concentration levels, respectively.

**Internal Standards (IS)** - are pure compounds with properties similar to the analytes of interest, which are added to field samples or extracts, calibration standards, and quality control standards at a known concentration. They are used to measure the relative responses of the analytes of interest and surrogates in the sample, calibration standard or quality control standard.

**Laboratory Duplicate (LD)** - is a field sample aliquot taken from the same sample container in the laboratory and analyzed separately using identical procedures. Analysis of laboratory duplicates provides a measure of the precision of the laboratory procedures.

**Laboratory Fortified Blank (LFB) / Laboratory Control Sample (LCS)** - is an aliquot of reagent water to which known concentrations of the analytes of interest are added. The LFB is analyzed exactly the same as the field samples. LFBs are used to determine whether the method is in control. FBL, FBM, and FBH are the LFB samples at low, mid, and high concentration levels, respectively.

**Laboratory Method Blank (LMB) / Laboratory Reagent Blank (LRB)** - is a sample of reagent water included in the sample batch analyzed in the same way as the associated field samples. The LMB is used to determine if method analytes or other background contamination have been introduced during the preparation or analytical procedure. The LMB is analyzed exactly the same as the field samples.

**Laboratory Trip Blank (LTB) / Field Reagent Blank (FRB)** - is a sample of laboratory reagent water placed in a sample container in the laboratory and treated as a field sample, including storage, preservation, and all analytical procedures. The FRB/LTB container follows the collection bottles to and from the collection site, but the FRB/LTB is not opened at any time during the trip. The FRB/LTB is primarily a travel blank used to verify that the samples were not contaminated during shipment.

**Matrix Spike Duplicate Sample (MSD) / Laboratory Fortified Sample Matrix Duplicate (LFSMD)** - is a sample aliquot taken from the same field sample source as the Matrix Spike Sample to which known quantities of the analytes of interest are added in the laboratory. The MSD is analyzed exactly the same as the field samples. Analysis of the MSD provides a measure of the precision of the laboratory procedures in a specific matrix. SDL, SDM, and SDH / LFSMDL, LFSMDM, and LFSMDH are the MSD or LFSMD at low, mid, and high concentration levels, respectively.

**Matrix Spike Sample (MS) / Laboratory Fortified Sample Matrix (LFSM)** - is a sample aliquot taken from field sample source to which known quantities of the analytes of interest are added in the laboratory. The MS is analyzed exactly the same as the field samples. The purpose is to demonstrate recovery of the analytes from a sample matrix to determine if the specific matrix contributes bias to the analytical results. MSL, MSM, and MSH / LFSML, LFSMM, and LFSMH are the MS or LFSM at low, mid, and high concentration levels, respectively.

**Quality Control Standard (QCS) / Second Source Calibration Verification (SSCV)** - is a solution containing known concentrations of the analytes of interest prepared from a source different from the source of the calibration standards. The solution is obtained from a second manufacturer or lot if the lot can be demonstrated by the manufacturer as prepared independently from other lots. The QCS sample is analyzed using the same procedures as field samples. The QCS is used as a check on the calibration standards used in the method on a routine basis.

**Reporting Limit Check (RLC) / Initial Calibration Check Standard (ICCS)** - is a procedural standard that is analyzed each day to evaluate instrument performance at or below the minimum reporting limit (MRL).

**Surrogate Standard (SS) / Surrogate Analyte (SUR)** - is a pure compound with properties similar to the analytes of interest, which is highly unlikely to be found in any field sample, that is added to the field samples, calibration standards, blanks and quality control standards before sample preparation. The SS is used to evaluate the efficiency of the sample preparation process.



Eaton Analytical

Order # 376763  
Batch # 468719

www.EurofinsUS.com/Eaton

### CHAIN OF CUSTODY RECORD

Page 1 of 1

REPORT TO:				SAMPLER (Signature)				PWS ID #		STATE (sample origin)		PROJECT NAME		PO#									
Juran more 719 322 2073								C0001275		CO		weekly											
BILL TO:				COMPLIANCE MONITORING		Yes		No		POPULATION SERVED		SOURCE WATER											
City of Fountain 116 S. Main St Fountain CO 80817								X		27,000		Agua Truck 3 pools		PFC									
LAB Number		COLLECTION				SAMPLING SITE				TEST NAME				SAMPLE REMARKS		CHLORINATED		# OF CONTAINERS		MATRIX CODE		TURNAROUND TIME	
		DATE		TIME		AM		PM								YES							
1	697	10-17-19	300		X	Agua NY				PFC 537 CL=A								X		2		2	
2	698	10-17-19	302		X	Agua S1				CL=A													
3	699	10-17-19	304		X	Agua S2				CL=A													
4	700	10-17-19	306		X	Agua S4				CL=A													
5	701	10-17-19	308		X	Agua RAN				CL=A													
6	702	10-17-19	315		X	Well 13 W4				CL=A													
7	703	10-17-19	317		X	Well 13 E1				CL=A													
8	704	10-17-19	319		X	Well 13 E2				CL=A													
9	705	10-17-19	322		X	Well 13 E4				CL=A													
10	706	10-17-19	324		X	Well 13 RAN				CL=A													
11																							
12																							
13																							
14																							

RELINQUISHED BY: (Signature)		DATE		TIME		RECEIVED BY: (Signature)		DATE		TIME		LAB RESERVES THE RIGHT TO RETURN UNUSED PORTIONS OF NON-AQUEOUS SAMPLES TO CLIENT	
		10-17-19		3:45								LAB COMMENTS	
RELINQUISHED BY: (Signature)		DATE		TIME		RECEIVED BY: (Signature)		DATE		TIME		CONDITIONS UPON RECEIPT (check one): Iced: Wet/Blue _____ Ambient _____ °C Upon Receipt <u>0.4</u> N/A	
RELINQUISHED BY: (Signature)		DATE		TIME		RECEIVED FOR LABORATORY BY:		DATE		TIME			
								10/18/19		1000			

MATRIX CODES:		TURN-AROUND TIME (TAT) - SURCHARGES			
DW-DRINKING WATER RW-REAGENT WATER GW-GROUND WATER EW-EXPOSURE WATER SW-SURFACE WATER PW-POOL WATER WW-WASTE WATER		SW = Standard Written: (15 working days) 0% RV* = Rush Verbal: (5 working days) 50% RW* = Rush Written: (5 working days) 75% IV* = Immediate Verbal: (3 working days) 100% IW* = Immediate Written: (3 working days) 125% SP* = Weekend, Holiday CALL STAT* = Less than 48 hours CALL			

\* Please call, expedited service not available for all testing

06-LO-F0435 Issue 7.0 Effective Date: 2018-10-11

Sample analysis will be provided according to the standard EEA/Water Services Terms, which are available upon request. Any other terms proposed by Customer are deemed material alterations and are rejected unless expressly agreed to in writing by EEA.