

LABORATORY REPORT

If you have any questions concerning this report, please do not hesitate to call the City of Fountain Water Department at (719) 322-2072

This report may not be reproduced, except in full, without written approval from EEA.

STATE CERTIFICATION LIST

State	Certification	State	Certification
Alabama	40700	Missouri	880
Alaska	IN00035	Montana	CERT0026
Arizona	AZ0432	Nebraska	NE-OS-05-04
Arkansas	IN00035	Nevada	IN00035
California	2920	New Hampshire*	2124
Colorado	IN00035	New Jersey*	IN598
Colorado Radiochemistry	IN00035	New Mexico	IN00035
Connecticut	PH-0132	New York*	11398
Delaware	IN035	North Carolina	18700
Florida*	E87775	North Dakota	R-035
Georgia	929	Ohio	87775
Hawaii	IN035	Oklahoma	D9508
Idaho	IN00035	Oregon (Primary AB)*	4074
Illinois*	200001	Pennsylvania*	68-00466
Illinois Microbiology	17767	Puerto Rico	IN00035
Illinois Radiochemistry	IN00035	Rhode Island	LAO00343
Indiana Chemistry	C-71-01	South Carolina	95005
Indiana Microbiology	M-76-07	South Dakota	IN00035
Iowa	098	Tennessee	TN02973
Kansas*	E-10233	Texas*	T104704187-18-12
Kentucky	90056	Texas/TCEQ	TX207
Louisiana*	LA014	Utah*	IN00035
Maine	IN00035	Vermont	VT-8775
Maryland	209	Virginia*	460275
Massachusetts	M-IN035	Washington	C837
Michigan	9926	West Virginia	9927 C
Minnesota*	018-999-338	Wisconsin	999766900
Mississippi	IN035	Wyoming	IN035
EPA	IN00035		

*NELAP/TNI Recognized Accreditation Bodies

Laboratory Report

Client: City of Fountain
Attn: Jasson Palmer
116 South Main
Fountain, CO 80817

Report: 475937
Priority: Standard Written
Status: Final
PWS ID: CO0121275

Sample Information					
EEA ID #	Client ID	Method	Collected Date / Time	Collected By:	Received Date / Time
4540869	Aga S1	537.1	01/15/20 14:00	Client	01/16/20 09:30
4540870	Aga S2	537.1	01/15/20 14:02	Client	01/16/20 09:30
4540871	Aga S4	537.1	01/15/20 14:04	Client	01/16/20 09:30
4540872	Aga N4	537.1	01/15/20 14:06	Client	01/16/20 09:30
4540873	Aga Raw	537.1	01/15/20 14:10	Client	01/16/20 09:30
4540874	Well 3 E1	537.1	01/15/20 14:20	Client	01/16/20 09:30
4540875	Well 3 E2	537.1	01/15/20 14:22	Client	01/16/20 09:30
4540876	Well 3 E4	537.1	01/15/20 14:24	Client	01/16/20 09:30
4540877	Well 3 W4	537.1	01/15/20 14:26	Client	01/16/20 09:30
4540878	Well 3 Raw	537.1	01/15/20 14:30	Client	01/16/20 09:30

Report Summary

Detailed quantitative results are presented on the following pages. The results presented relate only to the samples provided for analysis.

Note: This report may not be reproduced, except in full, without written approval from EEA.

Kelly Blackburn ASM

Authorized Signature

Title

02/04/2020

Date

Client Name: City of Fountain

Report #: 475937

Client Name: City of Fountain

Report #: 475937

Sampling Point: Aga S1

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
335-67-1	Perfluorooctanoic acid (PFOA)	537.1	---	2.0	2.8	ng/L	01/21/20 08:25	01/22/20 18:18	4540869
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537.1	---	2.0	< 2.0	ng/L	01/21/20 08:25	01/22/20 18:18	4540869
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537.1	---	2.0	15	ng/L	01/21/20 08:25	01/22/20 18:18	4540869
375-85-9	Perfluoroheptanoic acid (PFHpA)	537.1	---	2.0	2.4	ng/L	01/21/20 08:25	01/22/20 18:18	4540869
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537.1	---	2.0	3.3	ng/L	01/21/20 08:25	01/22/20 18:18	4540869
375-95-1	Perfluorononanoic acid (PFNA)	537.1	---	2.0	< 2.0	ng/L	01/21/20 08:25	01/22/20 18:18	4540869

Sampling Point: Aga S2

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
335-67-1	Perfluorooctanoic acid (PFOA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 17:52	4540870
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 17:52	4540870
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537.1	---	2.0	8.9	ng/L	01/22/20 07:30	01/23/20 17:52	4540870
375-85-9	Perfluoroheptanoic acid (PFHpA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 17:52	4540870
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 17:52	4540870
375-95-1	Perfluorononanoic acid (PFNA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 17:52	4540870

Sampling Point: Aga S4

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
335-67-1	Perfluorooctanoic acid (PFOA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 18:09	4540871
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 18:09	4540871
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 18:09	4540871
375-85-9	Perfluoroheptanoic acid (PFHpA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 18:09	4540871
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 18:09	4540871
375-95-1	Perfluorononanoic acid (PFNA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 18:09	4540871

Client Name: City of Fountain

Report #: 475937

Sampling Point: Aga N4

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
335-67-1	Perfluorooctanoic acid (PFOA)	537.1	---	2.0	7.0	ng/L	01/22/20 07:30	01/23/20 18:26	4540872
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537.1	---	2.0	2.7	ng/L	01/22/20 07:30	01/23/20 18:26	4540872
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537.1	---	2.0	19	ng/L	01/22/20 07:30	01/23/20 18:26	4540872
375-85-9	Perfluoroheptanoic acid (PFHpA)	537.1	---	2.0	3.9	ng/L	01/22/20 07:30	01/23/20 18:26	4540872
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537.1	---	2.0	10	ng/L	01/22/20 07:30	01/23/20 18:26	4540872
375-95-1	Perfluorononanoic acid (PFNA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 18:26	4540872

Sampling Point: Aga Raw

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
335-67-1	Perfluorooctanoic acid (PFOA)	537.1	---	2.0	21	ng/L	01/22/20 07:30	01/23/20 18:43	4540873
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537.1	---	2.0	24	ng/L	01/22/20 07:30	01/23/20 18:43	4540873
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537.1	---	2.0	28	ng/L	01/22/20 07:30	01/23/20 18:43	4540873
375-85-9	Perfluoroheptanoic acid (PFHpA)	537.1	---	2.0	7.7	ng/L	01/22/20 07:30	01/23/20 18:43	4540873
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537.1	---	2.0	38	ng/L	01/22/20 07:30	01/23/20 18:43	4540873
375-95-1	Perfluorononanoic acid (PFNA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 18:43	4540873

Sampling Point: Well 3 E1

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
335-67-1	Perfluorooctanoic acid (PFOA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:00	4540874
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:00	4540874
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:00	4540874
375-85-9	Perfluoroheptanoic acid (PFHpA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:00	4540874
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:00	4540874
375-95-1	Perfluorononanoic acid (PFNA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:00	4540874

Client Name: City of Fountain

Report #: 475937

Sampling Point: Well 3 E2

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
335-67-1	Perfluorooctanoic acid (PFOA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:17	4540875
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:17	4540875
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:17	4540875
375-85-9	Perfluoroheptanoic acid (PFHpA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:17	4540875
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:17	4540875
375-95-1	Perfluorononanoic acid (PFNA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:17	4540875

Sampling Point: Well 3 E4

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
335-67-1	Perfluorooctanoic acid (PFOA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:34	4540876
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:34	4540876
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:34	4540876
375-85-9	Perfluoroheptanoic acid (PFHpA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:34	4540876
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:34	4540876
375-95-1	Perfluorononanoic acid (PFNA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 19:34	4540876

Sampling Point: Well 3 W4

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
335-67-1	Perfluorooctanoic acid (PFOA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 20:07	4540877
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 20:07	4540877
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537.1	---	2.0	3.0	ng/L	01/22/20 07:30	01/23/20 20:07	4540877
375-85-9	Perfluoroheptanoic acid (PFHpA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 20:07	4540877
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 20:07	4540877
375-95-1	Perfluorononanoic acid (PFNA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 20:07	4540877

Client Name: City of Fountain

Report #: 475937

Sampling Point: Well 3 Raw

PWS ID: CO0121275

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
335-67-1	Perfluorooctanoic acid (PFOA)	537.1	---	2.0	14	ng/L	01/22/20 07:30	01/23/20 20:24	4540878
1763-23-1	Perfluorooctanesulfonic acid (PFOS)	537.1	---	2.0	26	ng/L	01/22/20 07:30	01/23/20 20:24	4540878
375-73-5	Perfluorobutanesulfonic acid (PFBS)	537.1	---	2.0	15	ng/L	01/22/20 07:30	01/23/20 20:24	4540878
375-85-9	Perfluoroheptanoic acid (PFHpA)	537.1	---	2.0	6.6	ng/L	01/22/20 07:30	01/23/20 20:24	4540878
355-46-4	Perfluorohexanesulfonic acid (PFHxS)	537.1	---	2.0	33	ng/L	01/22/20 07:30	01/23/20 20:24	4540878
375-95-1	Perfluorononanoic acid (PFNA)	537.1	---	2.0	< 2.0	ng/L	01/22/20 07:30	01/23/20 20:24	4540878

† EEA has demonstrated it can achieve these report limits in reagent water, but can not document them in all sample matrices.

Reg Limit Type:	MCL	SMCL	AL
Symbol:	*	^	!

Lab Definitions

Continuing Calibration Check Standard (CCC) / Continuing Calibration Verification (CCV) / Initial Calibration Verification Standard (ICV) / Initial Performance Check (IPC) - is a standard containing one or more of the target analytes that is prepared from the same standards used to calibrate the instrument. This standard is used to verify the calibration curve at the beginning of each analytical sequence, and may also be analyzed throughout and at the end of the sequence. The concentration of continuing standards may be varied, when prescribed by the reference method, so that the range of the calibration curve is verified on a regular basis. CCL, CCM, and CCH are the CCC standards at low, mid, and high concentration levels, respectively.

Internal Standards (IS) - are pure compounds with properties similar to the analytes of interest, which are added to field samples or extracts, calibration standards, and quality control standards at a known concentration. They are used to measure the relative responses of the analytes of interest and surrogates in the sample, calibration standard or quality control standard.

Laboratory Duplicate (LD) - is a field sample aliquot taken from the same sample container in the laboratory and analyzed separately using identical procedures. Analysis of laboratory duplicates provides a measure of the precision of the laboratory procedures.

Laboratory Fortified Blank (LFB) / Laboratory Control Sample (LCS) - is an aliquot of reagent water to which known concentrations of the analytes of interest are added. The LFB is analyzed exactly the same as the field samples. LFBs are used to determine whether the method is in control. FBL, FBM, and FBH are the LFB samples at low, mid, and high concentration levels, respectively.

Laboratory Method Blank (LMB) / Laboratory Reagent Blank (LRB) - is a sample of reagent water included in the sample batch analyzed in the same way as the associated field samples. The LMB is used to determine if method analytes or other background contamination have been introduced during the preparation or analytical procedure. The LMB is analyzed exactly the same as the field samples.

Laboratory Trip Blank (LTB) / Field Reagent Blank (FRB) - is a sample of laboratory reagent water placed in a sample container in the laboratory and treated as a field sample, including storage, preservation, and all analytical procedures. The FRB/LTB container follows the collection bottles to and from the collection site, but the FRB/LTB is not opened at any time during the trip. The FRB/LTB is primarily a travel blank used to verify that the samples were not contaminated during shipment.

Matrix Spike Duplicate Sample (MSD) / Laboratory Fortified Sample Matrix Duplicate (LFSMD) - is a sample aliquot taken from the same field sample source as the Matrix Spike Sample to which known quantities of the analytes of interest are added in the laboratory. The MSD is analyzed exactly the same as the field samples. Analysis of the MSD provides a measure of the precision of the laboratory procedures in a specific matrix. SDL, SDM, and SDH / LFSMDL, LFSMDM, and LFSMDH are the MSD or LFSMD at low, mid, and high concentration levels, respectively.

Matrix Spike Sample (MS) / Laboratory Fortified Sample Matrix (LFSM) - is a sample aliquot taken from field sample source to which known quantities of the analytes of interest are added in the laboratory. The MS is analyzed exactly the same as the field samples. The purpose is to demonstrate recovery of the analytes from a sample matrix to determine if the specific matrix contributes bias to the analytical results. MSL, MSM, and MSH / LFSML, LFSMM, and LFSMH are the MS or LFSM at low, mid, and high concentration levels, respectively.

Quality Control Standard (QCS) / Second Source Calibration Verification (SSCV) - is a solution containing known concentrations of the analytes of interest prepared from a source different from the source of the calibration standards. The solution is obtained from a second manufacturer or lot if the lot can be demonstrated by the manufacturer as prepared independently from other lots. The QCS sample is analyzed using the same procedures as field samples. The QCS is used as a check on the calibration standards used in the method on a routine basis.

Reporting Limit Check (RLC) / Initial Calibration Check Standard (ICCS) - is a procedural standard that is analyzed each day to evaluate instrument performance at or below the minimum reporting limit (MRL).

Surrogate Standard (SS) / Surrogate Analyte (SUR) - is a pure compound with properties similar to the analytes of interest, which is highly unlikely to be found in any field sample, that is added to the field samples, calibration standards, blanks and quality control standards before sample preparation. The SS is used to evaluate the efficiency of the sample preparation process.

CHAIN OF CUSTODY RECORD

Shaded area for EEA use only

REPORT TO: <u>Justin Moore</u> <u>719 322-2073</u>				SAMPLER (Signature) <u>[Signature]</u>				PWS ID # <u>CO00101075</u>		STATE (sample origin) <u>CO</u>		PROJECT NAME <u>Weekly PFL</u>		PO#											
BILL TO: <u>City of Fountain</u> <u>116 S. Main St Fountain CO 80817</u>				COMPLIANCE MONITORING		Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		POPULATION SERVED <u>27,000</u>		SOURCE WATER <u>Ag + well 13 pds</u>															
LAB Number		COLLECTION		DATE		TIME		AM		PM		SAMPLING SITE		TEST NAME		SAMPLE REMARKS		CHLORINATED		# OF CONTAINERS		MATRIX CODE		TURNAROUND TIME	
1	<u>4540869</u>	<u>1-15-20</u>	<u>200</u>	<u>X</u>				<u>Agg S1</u>	<u>PFL</u>	<u>PH 6.5-7.5</u>	<u>CI-A</u>	<u>X</u>		<u>2</u>	<u>2</u>	<u>SV</u>									
2	<u>870</u>	<u>1-15-20</u>	<u>202</u>	<u>X</u>				<u>Agg S2</u>	<u>PFL</u>	<u>PH 6.5-7.5</u>	<u>CI-A</u>	<u>X</u>		<u>2</u>	<u>2</u>	<u>SV</u>									
3	<u>871</u>	<u>1-15-20</u>	<u>204</u>	<u>X</u>				<u>Agg S4</u>	<u>PFL</u>	<u>PH 6.5-7.5</u>	<u>CI-A</u>	<u>X</u>		<u>2</u>	<u>2</u>	<u>SV</u>									
4	<u>872</u>	<u>1-15-20</u>	<u>206</u>	<u>X</u>				<u>Agg N4</u>	<u>PFL</u>	<u>PH 6.5-7.5</u>	<u>CI-A</u>	<u>X</u>		<u>2</u>	<u>2</u>	<u>SV</u>									
5	<u>873</u>	<u>1-15-20</u>	<u>210</u>	<u>X</u>				<u>Agg Run</u>	<u>PFL</u>	<u>PH 6.5-7.5</u>	<u>CI-A</u>	<u>X</u>		<u>2</u>	<u>2</u>	<u>SV</u>									
6	<u>874</u>	<u>1-15-20</u>	<u>220</u>	<u>X</u>				<u>Well 3 E1</u>	<u>PFL</u>	<u>PH 6.5-7.5</u>	<u>CI-A</u>	<u>X</u>		<u>2</u>	<u>2</u>	<u>SV</u>									
7	<u>875</u>	<u>1-15-20</u>	<u>222</u>	<u>X</u>				<u>Well 3 E2</u>	<u>PFL</u>	<u>PH 6.5-7.5</u>	<u>CI-A</u>	<u>X</u>		<u>2</u>	<u>2</u>	<u>SV</u>									
8	<u>876</u>	<u>1-15-20</u>	<u>224</u>	<u>X</u>				<u>Well 3 E4</u>	<u>PFL</u>	<u>PH 6.5-7.5</u>	<u>CI-A</u>	<u>X</u>		<u>2</u>	<u>2</u>	<u>SV</u>									
9	<u>877</u>	<u>1-15-20</u>	<u>226</u>	<u>X</u>				<u>Well 3 W4</u>	<u>PFL</u>	<u>PH 6.5-7.5</u>	<u>CI-A</u>	<u>X</u>		<u>2</u>	<u>2</u>	<u>SV</u>									
10	<u>878</u>	<u>1-15-20</u>	<u>230</u>	<u>X</u>				<u>Well 3 Lin</u>	<u>PFL</u>	<u>PH 6.5-7.5</u>	<u>CI-A</u>	<u>X</u>		<u>2</u>	<u>2</u>	<u>SV</u>									
11																									
12																									
13																									
14																									

Cross Offs on COC by Client

SS 1-16-2020

RELINQUISHED BY: (Signature) <u>[Signature]</u>	DATE <u>1-15-20</u>	TIME <u>845</u>	RECEIVED BY: (Signature) <u>[Signature]</u>	DATE	TIME	LAB RESERVES THE RIGHT TO RETURN UNUSED PORTIONS OF NON-AQUEOUS SAMPLES TO CLIENT	
RELINQUISHED BY: (Signature)	DATE	TIME	RECEIVED BY: (Signature)	DATE	TIME	LAB COMMENTS	
RELINQUISHED BY: (Signature)	DATE	TIME	RECEIVED FOR LABORATORY BY: <u>[Signature]</u>	DATE <u>1-16-2020</u>	TIME <u>0930</u>	CONDITIONS UPON RECEIPT (check one): <u>X</u> Iced: Wet/Blue <u>0</u> Ambient <u>0</u> °C Upon Receipt <u>0</u> N/A	

MATRIX CODES:

DW-DRINKING WATER
RW-REAGENT WATER
GW-GROUND WATER
EW-EXPOSURE WATER
SW-SURFACE WATER
PW-POOL WATER
WW-WASTE WATER

TURN-AROUND TIME (TAT) - SURCHARGES

SW = Standard Written: (15 working days) 0%
RV = Rush Verbal: (5 working days) 50%
RW = Rush Written: (5 working days) 75%

IV = Immediate Verbal: (3 working days) 100%
IW = Immediate Written: (3 working days) 125%
SP = Weekend, Holiday CALL
STAT = Less than 48 hours CALL

* Please call, expedited service not available for all testing