

LABORATORY REPORT

If you have any questions concerning this report, please do not hesitate to call the City of Fountain Water Department at (719) 322-2072

This report may not be reproduced, except in full, without written approval from EEA.

STATE CERTIFICATION LIST

| State | Certification | State | Certification |
|-------------------------|---------------|----------------------|------------------|
| Alabama | 40700 | Missouri | 880 |
| Alaska | IN00035 | Montana | CERT0026 |
| Arizona | AZ0432 | Nebraska | NE-OS-05-04 |
| Arkansas | IN00035 | Nevada | IN00035 |
| California | 2920 | New Hampshire* | 2124 |
| Colorado | IN00035 | New Jersey* | IN598 |
| Colorado Radiochemistry | IN00035 | New Mexico | IN00035 |
| Connecticut | PH-0132 | New York* | 11398 |
| Delaware | IN035 | North Carolina | 18700 |
| Florida* | E87775 | North Dakota | R-035 |
| Georgia | 929 | Ohio | 87775 |
| Hawaii | IN035 | Oklahoma | D9508 |
| Idaho | IN00035 | Oregon (Primary AB)* | 4074 |
| Illinois* | 200001 | Pennsylvania* | 68-00466 |
| Illinois Microbiology | 17767 | Puerto Rico | IN00035 |
| Illinois Radiochemistry | IN00035 | Rhode Island | LAO00343 |
| Indiana Chemistry | C-71-01 | South Carolina | 95005 |
| Indiana Microbiology | M-76-07 | South Dakota | IN00035 |
| Iowa | 098 | Tennessee | TN02973 |
| Kansas* | E-10233 | Texas* | T104704187-18-12 |
| Kentucky | 90056 | Texas/TCEQ | TX207 |
| Louisiana* | LA014 | Utah* | IN00035 |
| Maine | IN00035 | Vermont | VT-8775 |
| Maryland | 209 | Virginia* | 460275 |
| Massachusetts | M-IN035 | Washington | C837 |
| Michigan | 9926 | West Virginia | 9927 C |
| Minnesota* | 018-999-338 | Wisconsin | 999766900 |
| Mississippi | IN035 | Wyoming | IN035 |
| EPA | IN00035 | | |

*NELAP/TNI Recognized Accreditation Bodies

Laboratory Report

Client: City of Fountain
Attn: Jasson Palmer
116 South Main
Fountain, CO 80817

Report: 479143
Priority: Standard Written
Status: Final
PWS ID: CO0121275

| Sample Information | | | | | |
|--------------------|-------------|--------|-----------------------|---------------|----------------------|
| EEA ID # | Client ID | Method | Collected Date / Time | Collected By: | Received Date / Time |
| 4570761 | Aga S-2 | 537.1 | 02/20/20 14:00 | Client | 02/21/20 09:15 |
| 4570762 | Aga S-3 | 537.1 | 02/20/20 14:02 | Client | 02/21/20 09:15 |
| 4570763 | Aga S-4 | 537.1 | 02/20/20 14:04 | Client | 02/21/20 09:15 |
| 4570764 | Aga N-2 | 537.1 | 02/20/20 14:06 | Client | 02/21/20 09:15 |
| 4570765 | Aga Raw | 537.1 | 02/20/20 14:08 | Client | 02/21/20 09:15 |
| 4570766 | Well #3 E-1 | 537.1 | 02/20/20 14:22 | Client | 02/21/20 09:15 |
| 4570767 | Well #3 E-2 | 537.1 | 02/20/20 14:24 | Client | 02/21/20 09:15 |
| 4570768 | Well #3 E-4 | 537.1 | 02/20/20 14:26 | Client | 02/21/20 09:15 |
| 4570769 | Well #3 W-4 | 537.1 | 02/20/20 14:28 | Client | 02/21/20 09:15 |
| 4570770 | Well #3 Raw | 537.1 | 02/20/20 14:30 | Client | 02/21/20 09:15 |

Report Summary

Detailed quantitative results are presented on the following pages. The results presented relate only to the samples provided for analysis.

Note: This report may not be reproduced, except in full, without written approval from EEA.

Kelly Blackburn ASM

Authorized Signature

Title

03/06/2020

Date

Client Name: City of Fountain

Report #: 479143

Client Name: City of Fountain

Report #: 479143

Sampling Point: Aga S-2

PWS ID: CO0121275

| EEA Methods | | | | | | | | | |
|--------------|--------------------------------------|--------|-----------|------|------------|-------|------------------|----------------|----------|
| Analyte ID # | Analyte | Method | Reg Limit | MRL† | Result | Units | Preparation Date | Analyzed Date | EEA ID # |
| 335-67-1 | Perfluorooctanoic acid (PFOA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 07:30 | 4570761 |
| 1763-23-1 | Perfluorooctanesulfonic acid (PFOS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 07:30 | 4570761 |
| 375-73-5 | Perfluorobutanesulfonic acid (PFBS) | 537.1 | --- | 2.0 | 15 | ng/L | 02/28/20 08:25 | 02/29/20 07:30 | 4570761 |
| 375-85-9 | Perfluoroheptanoic acid (PFHpA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 07:30 | 4570761 |
| 355-46-4 | Perfluorohexanesulfonic acid (PFHxS) | 537.1 | --- | 2.0 | 2.2 | ng/L | 02/28/20 08:25 | 02/29/20 07:30 | 4570761 |
| 375-95-1 | Perfluorononanoic acid (PFNA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 07:30 | 4570761 |

Sampling Point: Aga S-3

PWS ID: CO0121275

| EEA Methods | | | | | | | | | |
|--------------|--------------------------------------|--------|-----------|------|------------|-------|------------------|----------------|----------|
| Analyte ID # | Analyte | Method | Reg Limit | MRL† | Result | Units | Preparation Date | Analyzed Date | EEA ID # |
| 335-67-1 | Perfluorooctanoic acid (PFOA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 07:43 | 4570762 |
| 1763-23-1 | Perfluorooctanesulfonic acid (PFOS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 07:43 | 4570762 |
| 375-73-5 | Perfluorobutanesulfonic acid (PFBS) | 537.1 | --- | 2.0 | 9.6 | ng/L | 02/28/20 08:25 | 02/29/20 07:43 | 4570762 |
| 375-85-9 | Perfluoroheptanoic acid (PFHpA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 07:43 | 4570762 |
| 355-46-4 | Perfluorohexanesulfonic acid (PFHxS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 07:43 | 4570762 |
| 375-95-1 | Perfluorononanoic acid (PFNA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 07:43 | 4570762 |

Sampling Point: Aga S-4

PWS ID: CO0121275

| EEA Methods | | | | | | | | | |
|--------------|--------------------------------------|--------|-----------|------|------------|-------|------------------|----------------|----------|
| Analyte ID # | Analyte | Method | Reg Limit | MRL† | Result | Units | Preparation Date | Analyzed Date | EEA ID # |
| 335-67-1 | Perfluorooctanoic acid (PFOA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 08:09 | 4570763 |
| 1763-23-1 | Perfluorooctanesulfonic acid (PFOS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 08:09 | 4570763 |
| 375-73-5 | Perfluorobutanesulfonic acid (PFBS) | 537.1 | --- | 2.0 | 4.5 | ng/L | 02/28/20 08:25 | 02/29/20 08:09 | 4570763 |
| 375-85-9 | Perfluoroheptanoic acid (PFHpA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 08:09 | 4570763 |
| 355-46-4 | Perfluorohexanesulfonic acid (PFHxS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 08:09 | 4570763 |
| 375-95-1 | Perfluorononanoic acid (PFNA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 08:09 | 4570763 |

Client Name: City of Fountain

Report #: 479143

Sampling Point: Aga N-2

PWS ID: CO0121275

| EEA Methods | | | | | | | | | |
|--------------|--------------------------------------|--------|-----------|------|--------|-------|------------------|----------------|----------|
| Analyte ID # | Analyte | Method | Reg Limit | MRL† | Result | Units | Preparation Date | Analyzed Date | EEA ID # |
| 335-67-1 | Perfluorooctanoic acid (PFOA) | 537.1 | --- | 2.0 | 8.4 | ng/L | 02/28/20 08:25 | 02/29/20 08:22 | 4570764 |
| 1763-23-1 | Perfluorooctanesulfonic acid (PFOS) | 537.1 | --- | 2.0 | 3.1 | ng/L | 02/28/20 08:25 | 02/29/20 08:22 | 4570764 |
| 375-73-5 | Perfluorobutanesulfonic acid (PFBS) | 537.1 | --- | 2.0 | 25 | ng/L | 02/28/20 08:25 | 02/29/20 08:22 | 4570764 |
| 375-85-9 | Perfluoroheptanoic acid (PFHpA) | 537.1 | --- | 2.0 | 4.8 | ng/L | 02/28/20 08:25 | 02/29/20 08:22 | 4570764 |
| 355-46-4 | Perfluorohexanesulfonic acid (PFHxS) | 537.1 | --- | 2.0 | 13 | ng/L | 02/28/20 08:25 | 02/29/20 08:22 | 4570764 |
| 375-95-1 | Perfluorononanoic acid (PFNA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 02/28/20 08:25 | 02/29/20 08:22 | 4570764 |

Sampling Point: Aga Raw

PWS ID: CO0121275

| EEA Methods | | | | | | | | | |
|--------------|--------------------------------------|--------|-----------|------|--------|-------|------------------|----------------|----------|
| Analyte ID # | Analyte | Method | Reg Limit | MRL† | Result | Units | Preparation Date | Analyzed Date | EEA ID # |
| 335-67-1 | Perfluorooctanoic acid (PFOA) | 537.1 | --- | 2.0 | 21 | ng/L | 03/03/20 07:30 | 03/04/20 21:52 | 4570765 |
| 1763-23-1 | Perfluorooctanesulfonic acid (PFOS) | 537.1 | --- | 2.0 | 25 | ng/L | 03/03/20 07:30 | 03/04/20 21:52 | 4570765 |
| 375-73-5 | Perfluorobutanesulfonic acid (PFBS) | 537.1 | --- | 2.0 | 36 | ng/L | 03/03/20 07:30 | 03/04/20 21:52 | 4570765 |
| 375-85-9 | Perfluoroheptanoic acid (PFHpA) | 537.1 | --- | 2.0 | 8.3 | ng/L | 03/03/20 07:30 | 03/04/20 21:52 | 4570765 |
| 355-46-4 | Perfluorohexanesulfonic acid (PFHxS) | 537.1 | --- | 2.0 | 43 | ng/L | 03/03/20 07:30 | 03/04/20 21:52 | 4570765 |
| 375-95-1 | Perfluorononanoic acid (PFNA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 21:52 | 4570765 |

Sampling Point: Well #3 E-1

PWS ID: CO0121275

| EEA Methods | | | | | | | | | |
|--------------|--------------------------------------|--------|-----------|------|--------|-------|------------------|----------------|----------|
| Analyte ID # | Analyte | Method | Reg Limit | MRL† | Result | Units | Preparation Date | Analyzed Date | EEA ID # |
| 335-67-1 | Perfluorooctanoic acid (PFOA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:05 | 4570766 |
| 1763-23-1 | Perfluorooctanesulfonic acid (PFOS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:05 | 4570766 |
| 375-73-5 | Perfluorobutanesulfonic acid (PFBS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:05 | 4570766 |
| 375-85-9 | Perfluoroheptanoic acid (PFHpA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:05 | 4570766 |
| 355-46-4 | Perfluorohexanesulfonic acid (PFHxS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:05 | 4570766 |
| 375-95-1 | Perfluorononanoic acid (PFNA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:05 | 4570766 |

Client Name: City of Fountain

Report #: 479143

Sampling Point: Well #3 E-2

PWS ID: CO0121275

| EEA Methods | | | | | | | | | |
|--------------|--------------------------------------|--------|-----------|------|--------|-------|------------------|----------------|----------|
| Analyte ID # | Analyte | Method | Reg Limit | MRL† | Result | Units | Preparation Date | Analyzed Date | EEA ID # |
| 335-67-1 | Perfluorooctanoic acid (PFOA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:31 | 4570767 |
| 1763-23-1 | Perfluorooctanesulfonic acid (PFOS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:31 | 4570767 |
| 375-73-5 | Perfluorobutanesulfonic acid (PFBS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:31 | 4570767 |
| 375-85-9 | Perfluoroheptanoic acid (PFHpA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:31 | 4570767 |
| 355-46-4 | Perfluorohexanesulfonic acid (PFHxS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:31 | 4570767 |
| 375-95-1 | Perfluorononanoic acid (PFNA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:31 | 4570767 |

Sampling Point: Well #3 E-4

PWS ID: CO0121275

| EEA Methods | | | | | | | | | |
|--------------|--------------------------------------|--------|-----------|------|--------|-------|------------------|----------------|----------|
| Analyte ID # | Analyte | Method | Reg Limit | MRL† | Result | Units | Preparation Date | Analyzed Date | EEA ID # |
| 335-67-1 | Perfluorooctanoic acid (PFOA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:57 | 4570768 |
| 1763-23-1 | Perfluorooctanesulfonic acid (PFOS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:57 | 4570768 |
| 375-73-5 | Perfluorobutanesulfonic acid (PFBS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:57 | 4570768 |
| 375-85-9 | Perfluoroheptanoic acid (PFHpA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:57 | 4570768 |
| 355-46-4 | Perfluorohexanesulfonic acid (PFHxS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:57 | 4570768 |
| 375-95-1 | Perfluorononanoic acid (PFNA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 22:57 | 4570768 |

Sampling Point: Well #3 W-4

PWS ID: CO0121275

| EEA Methods | | | | | | | | | |
|--------------|--------------------------------------|--------|-----------|------|------------|-------|------------------|----------------|----------|
| Analyte ID # | Analyte | Method | Reg Limit | MRL† | Result | Units | Preparation Date | Analyzed Date | EEA ID # |
| 335-67-1 | Perfluorooctanoic acid (PFOA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 23:10 | 4570769 |
| 1763-23-1 | Perfluorooctanesulfonic acid (PFOS) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 23:10 | 4570769 |
| 375-73-5 | Perfluorobutanesulfonic acid (PFBS) | 537.1 | --- | 2.0 | 4.4 | ng/L | 03/03/20 07:30 | 03/04/20 23:10 | 4570769 |
| 375-85-9 | Perfluoroheptanoic acid (PFHpA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 23:10 | 4570769 |
| 355-46-4 | Perfluorohexanesulfonic acid (PFHxS) | 537.1 | --- | 2.0 | 2.1 | ng/L | 03/03/20 07:30 | 03/04/20 23:10 | 4570769 |
| 375-95-1 | Perfluorononanoic acid (PFNA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 23:10 | 4570769 |

Client Name: City of Fountain

Report #: 479143

Sampling Point: Well #3 Raw

PWS ID: CO0121275

| EEA Methods | | | | | | | | | |
|--------------|--------------------------------------|--------|-----------|------|--------|-------|------------------|----------------|----------|
| Analyte ID # | Analyte | Method | Reg Limit | MRL† | Result | Units | Preparation Date | Analyzed Date | EEA ID # |
| 335-67-1 | Perfluorooctanoic acid (PFOA) | 537.1 | --- | 2.0 | 14 | ng/L | 03/03/20 07:30 | 03/04/20 23:23 | 4570770 |
| 1763-23-1 | Perfluorooctanesulfonic acid (PFOS) | 537.1 | --- | 2.0 | 26 | ng/L | 03/03/20 07:30 | 03/04/20 23:23 | 4570770 |
| 375-73-5 | Perfluorobutanesulfonic acid (PFBS) | 537.1 | --- | 2.0 | 20 | ng/L | 03/03/20 07:30 | 03/04/20 23:23 | 4570770 |
| 375-85-9 | Perfluoroheptanoic acid (PFHpA) | 537.1 | --- | 2.0 | 7.0 | ng/L | 03/03/20 07:30 | 03/04/20 23:23 | 4570770 |
| 355-46-4 | Perfluorohexanesulfonic acid (PFHxS) | 537.1 | --- | 2.0 | 39 | ng/L | 03/03/20 07:30 | 03/04/20 23:23 | 4570770 |
| 375-95-1 | Perfluorononanoic acid (PFNA) | 537.1 | --- | 2.0 | < 2.0 | ng/L | 03/03/20 07:30 | 03/04/20 23:23 | 4570770 |

† EEA has demonstrated it can achieve these report limits in reagent water, but can not document them in all sample matrices.

| | | | |
|-----------------|-----|------|----|
| Reg Limit Type: | MCL | SMCL | AL |
| Symbol: | * | ^ | ! |

Lab Definitions

Continuing Calibration Check Standard (CCC) / Continuing Calibration Verification (CCV) / Initial Calibration Verification Standard (ICV) / Initial Performance Check (IPC) - is a standard containing one or more of the target analytes that is prepared from the same standards used to calibrate the instrument. This standard is used to verify the calibration curve at the beginning of each analytical sequence, and may also be analyzed throughout and at the end of the sequence. The concentration of continuing standards may be varied, when prescribed by the reference method, so that the range of the calibration curve is verified on a regular basis. CCL, CCM, and CCH are the CCC standards at low, mid, and high concentration levels, respectively.

Internal Standards (IS) - are pure compounds with properties similar to the analytes of interest, which are added to field samples or extracts, calibration standards, and quality control standards at a known concentration. They are used to measure the relative responses of the analytes of interest and surrogates in the sample, calibration standard or quality control standard.

Laboratory Duplicate (LD) - is a field sample aliquot taken from the same sample container in the laboratory and analyzed separately using identical procedures. Analysis of laboratory duplicates provides a measure of the precision of the laboratory procedures.

Laboratory Fortified Blank (LFB) / Laboratory Control Sample (LCS) - is an aliquot of reagent water to which known concentrations of the analytes of interest are added. The LFB is analyzed exactly the same as the field samples. LFBs are used to determine whether the method is in control. FBL, FBM, and FBH are the LFB samples at low, mid, and high concentration levels, respectively.

Laboratory Method Blank (LMB) / Laboratory Reagent Blank (LRB) - is a sample of reagent water included in the sample batch analyzed in the same way as the associated field samples. The LMB is used to determine if method analytes or other background contamination have been introduced during the preparation or analytical procedure. The LMB is analyzed exactly the same as the field samples.

Laboratory Trip Blank (LTB) / Field Reagent Blank (FRB) - is a sample of laboratory reagent water placed in a sample container in the laboratory and treated as a field sample, including storage, preservation, and all analytical procedures. The FRB/LTB container follows the collection bottles to and from the collection site, but the FRB/LTB is not opened at any time during the trip. The FRB/LTB is primarily a travel blank used to verify that the samples were not contaminated during shipment.

Matrix Spike Duplicate Sample (MSD) / Laboratory Fortified Sample Matrix Duplicate (LFSMD) - is a sample aliquot taken from the same field sample source as the Matrix Spike Sample to which known quantities of the analytes of interest are added in the laboratory. The MSD is analyzed exactly the same as the field samples. Analysis of the MSD provides a measure of the precision of the laboratory procedures in a specific matrix. SDL, SDM, and SDH / LFSMDL, LFSMDM, and LFSMDH are the MSD or LFSMD at low, mid, and high concentration levels, respectively.

Matrix Spike Sample (MS) / Laboratory Fortified Sample Matrix (LFSM) - is a sample aliquot taken from field sample source to which known quantities of the analytes of interest are added in the laboratory. The MS is analyzed exactly the same as the field samples. The purpose is to demonstrate recovery of the analytes from a sample matrix to determine if the specific matrix contributes bias to the analytical results. MSL, MSM, and MSH / LFSML, LFSMM, and LFSMH are the MS or LFSM at low, mid, and high concentration levels, respectively.

Quality Control Standard (QCS) / Second Source Calibration Verification (SSCV) - is a solution containing known concentrations of the analytes of interest prepared from a source different from the source of the calibration standards. The solution is obtained from a second manufacturer or lot if the lot can be demonstrated by the manufacturer as prepared independently from other lots. The QCS sample is analyzed using the same procedures as field samples. The QCS is used as a check on the calibration standards used in the method on a routine basis.

Reporting Limit Check (RLC) / Initial Calibration Check Standard (ICCS) - is a procedural standard that is analyzed each day to evaluate instrument performance at or below the minimum reporting limit (MRL).

Surrogate Standard (SS) / Surrogate Analyte (SUR) - is a pure compound with properties similar to the analytes of interest, which is highly unlikely to be found in any field sample, that is added to the field samples, calibration standards, blanks and quality control standards before sample preparation. The SS is used to evaluate the efficiency of the sample preparation process.



Eaton Analytical

Order # 389216
Batch # 479143

www.EurofinsUS.com/Eaton

CHAIN OF CUSTODY RECORD

Page 1 of 1

| Shaded area for EEA use only | | | | CHAIN OF CUSTODY RECORD | | | | | | | | | | Page <u>1</u> of <u>1</u> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|--|--|--|-------------------------|--|--|--|-------------------|--|-----------------------|--|------------------------|--|---------------------------|--|-----------------|-------------|-----------------|--|---------------|--|--|--|---|--|--|--|---|--|--|--|---|--|--|--|----|--|--|--|----|--|--|--|
| REPORT TO: | | | | SAMPLER (Signature) | | | | PWS ID # | | STATE (sample origin) | | PROJECT NAME | | PO# | | # OF CONTAINERS | MATRIX CODE | TURNAROUND TIME | | | | | | | | | | | | | | | | | | | | | | | | | |
| Justin Moore 719-322-2073 | | | | <i>[Signature]</i> | | | | CO 8121275 | | CO | | Weekly | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| BILL TO: City of Fountain 116 S. Main St. Fountain CO 80817 | | | | COMPLIANCE MONITORING | | | | POPULATION SERVED | | SOURCE WATER | | PFC | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | Yes | | | | No | | 27,000 | | Aga + well 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| LAB Number | | | | COLLECTION | | | | pH Acceptable | | | | TEST NAME Chlorine A/P | | | | CHLORINATED | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | DATE | | | | TIME | | | | AM | | | | PM | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | | | | 2-20-20 | | | | 2:00 | | | | X | | | | Aga S-2 | | | | 531.1 4570761 | | | | A | | | | X | | | | 2 | | | | DW | | | | SW | | | |
| 2 | | | | 2-20-20 | | | | 2:02 | | | | X | | | | Aga S-3 | | | | 762 | | | | A | | | | X | | | | 2 | | | | DW | | | | SW | | | |
| 3 | | | | 2-20-20 | | | | 2:04 | | | | X | | | | Aga S-4 | | | | 763 | | | | A | | | | X | | | | 2 | | | | DW | | | | SW | | | |
| 4 | | | | 2-20-20 | | | | 2:06 | | | | X | | | | Aga N-4 | | | | 764 | | | | A | | | | X | | | | 2 | | | | DW | | | | SW | | | |
| 5 | | | | 2-20-20 | | | | 2:08 | | | | X | | | | Aga Raw | | | | 765 | | | | A | | | | X | | | | 2 | | | | DW | | | | SW | | | |
| 6 | | | | 2-20-20 | | | | 2:22 | | | | X | | | | well #3 E-1 | | | | 766 | | | | A | | | | X | | | | 2 | | | | DW | | | | SW | | | |
| 7 | | | | 2-20-20 | | | | 2:24 | | | | X | | | | well #3 E-2 | | | | 767 | | | | A | | | | X | | | | 2 | | | | DW | | | | SW | | | |
| 8 | | | | 2-20-20 | | | | 2:26 | | | | X | | | | well #3 E-4 | | | | 768 | | | | A | | | | X | | | | 2 | | | | DW | | | | SW | | | |
| 9 | | | | 2-20-20 | | | | 2:28 | | | | X | | | | well #3 W-4 | | | | 769 | | | | A | | | | X | | | | 2 | | | | DW | | | | SW | | | |
| 10 | | | | 2-20-20 | | | | 2:30 | | | | X | | | | well #3 Raw | | | | 770 | | | | A | | | | X | | | | 2 | | | | DW | | | | SW | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 13 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 14 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Client used white-out on COC.

| RELINQUISHED BY: (Signature) | | DATE | | TIME | | RECEIVED BY: (Signature) | | DATE | | TIME | | LAB RESERVES THE RIGHT TO RETURN UNUSED PORTIONS OF NON-AQUEOUS SAMPLES TO CLIENT | |
|------------------------------|--|---------|--|------|--|-----------------------------|--|-----------|--|------|--|---|--|
| <i>[Signature]</i> | | 2/20/20 | | 2:45 | | <i>[Signature]</i> | | | | | | LAB COMMENTS | |
| RELINQUISHED BY: (Signature) | | DATE | | TIME | | RECEIVED BY: (Signature) | | DATE | | TIME | | | |
| | | | | | | | | | | | | | |
| RELINQUISHED BY: (Signature) | | DATE | | TIME | | RECEIVED FOR LABORATORY BY: | | DATE | | TIME | | CONDITIONS UPON RECEIPT (check one): | |
| | | | | | | <i>[Signature]</i> | | 2-21-2020 | | 0915 | | X Iced: Wet/Blue _____ Ambient _____ °C Upon Receipt _____ N/A | |

MATRIX CODES:

DW-DRINKING WATER
RW-REAGENT WATER
GW-GROUND WATER
EW-EXPOSURE WATER
SW-SURFACE WATER
PW-POOL WATER
WW-WASTE WATER

TURN-AROUND TIME (TAT) - SURCHARGES

SW = Standard Written: (15 working days) 0%
RV* = Rush Verbal: (5 working days) 50%
RW* = Rush Written: (5 working days) 75%

* Please call, expedited service not available for all testing

IV* = Immediate Verbal: (3 working days) 100%
IW* = Immediate Written: (3 working days) 125%
SP* = Weekend, Holiday CALL
STAT* = Less than 48 hours CALL

Samples received unannounced with less than 48 hours holding time remaining may be subject to additional charges.

06-LO-F0435 Issue 7.0 Effective Date: 2018-10-11

Sample analysis will be provided according to the standard EEA/Water Services Terms, which are available upon request. Any other terms proposed by Customer are deemed material alterations and are rejected unless expressly agreed to in writing by EEA.